



Food Vendors Check List for The Great Frederick Fair 2025

Mobile Food Truck/Trailer & Permanent Food Stands:

If equipped with gas appliances, you **must** have the following:

- Carbon monoxide detector (less than 10 years old)
- Combustible gas detector (less than 10 years old)
- "No smoking" signage on or near gas cylinder(s)
- Gas cylinders need to be secured
- Gas cylinders located in a compartment should be vented and accessible from the outside only
- ABC fire extinguisher (serviced or purchased within last 12 months)
- General maintenance and cleaning is required

If equipment produces grease laden vapors, you **must** have the following:

- Hood system (serviced or purchased within last 12 months)
- Class K fire extinguisher
- General maintenance and cleaning is required

If equipped with grilling/cooking equipment, you **must** have the following:

- ABC fire extinguisher (serviced or purchased within last 12 months)
- General maintenance and cleaning is required

Food Tents:

If equipped with gas appliances, you **must** have the following:

- "No smoking" signage on or near gas cylinder(s)
- Gas cylinders need to be secured.
- ABC fire extinguisher (serviced or purchased within last 12 months)
- General maintenance and cleaning is required

If equipment produces grease laden vapors, you **must** have the following:

- Class K fire extinguisher (serviced or purchased within last 12 months)
- Flame resistant label on the tent that complies to NFPA 701 or equivalent.
- General maintenance and cleaning is required

If equipped with grilling/cooking equipment, you **must** have the following:

- ABC fire extinguisher (serviced or purchased within last 12 months)
- Flame resistant label on the tent that complies to NFPA 701 or equivalent.
- General maintenance and cleaning is required

Examples of required equipment can be found on the next page. Questions can be directed to the Office of The Fire Marshal Dfrsfiremarshal@frederickcountymd.gov or 301-600-1479.





Example of a combustible Gas/Co detector combo unit: - Shown below



Hcmltek Gas Leak Detector, Natural Gas Detector and Plug in Carbon Monoxide Detector for Home, Kitchen, Combustible Gas Leak Detector Monitor for CO, LNG, LPG, Methane

Example of Full Home ABC Fire Extinguisher with Hose, 3-A:40-B:C, Dry Chemical, One-Time Use



Propane hazard signage for the exterior of the vehicle



No Smoking Sign – Placed near flammable liquids



Gas Shut Off Sign

